

 CDM project activity issuance review form <i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i>	
Designated national authority/Executive Board member submitting this form (Name in print)	
Title of the proposed CDM project activity for which issuance is requested	0203 Cerradinho Bagasse Cogeneration Project (CBCP)
DOE that requested for issuance and date of request	DNV 31.07.2007
Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)	
___ <i>Fraud</i> ___ <i>Malfeasance</i> <u>X</u> <i>Incompetence</i>	
Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)	
<ol style="list-style-type: none"> The changes from one 30 MW unit to 2x25 MW units suggest that more bagasse was available to be used in the facility. Since both units were installed after the project activity was registered, clarification is required as to how the requirements of AM0015 have been complied with by the project activity, i.e. that: <ul style="list-style-type: none"> – The bagasse to be used as the feedstock for cogeneration shall be supplied from the same facility where the project is implemented; – The implementation of the project shall not increase the bagasse production in the facility Additional information is required on the cane crushing capacity prior to and after the implementation of the project activity. The PDD states that the grid emission factor is to be calculated 'At the validation and yearly after registration', while the verification report indicates ex-ante. Clarification is required. 	
Section below to be filled in by UNFCCC secretariat	
Date received at UNFCCC secretariat	12/09/2007