

Calibration Performa

Department: Instrument

Instrument Tag: TE-02102-15 B Instrument Name: RTD
 P&I No /Location: D-13310-0 Range: 30 ~ 100 °C
 Calibration Frequency: one year Instrument used for calibration: Temp Bath
 Reference Document: OS-32 Plant: Nitric Acid
 Acceptable Error: _____

Result Before Calibration:

Reference Data	Observed Data	Error (If any)
30 °C	111.67 Ω	/ No /
40 °C	115.53 Ω	
60 °C	123.25 Ω	
80 °C	130.90 Ω	
100 °C	138.51 Ω	

Result After Calibration:

Reference Data	Observed Data	Error (If any)
/	/	/
/	/	/
/	/	/
/	/	/
/	/	/

Remarks (If Any): _____

<u>17-09-2007</u> Date of Calibration	<u>16-09-2008</u> Next Due Date	<u>Saif + Munira</u> Calibrated By
--	------------------------------------	---------------------------------------