

Calibration Performa

Department: Instrument

Instrument Tag: TE-02102-15A

Instrument Name: RTD

P&I No /Location: D-13310-0

Range: 30 ~ 100 °C

Calibration Frequency: one year

Instrument used for calibration: Temp Bath

Reference Document: 05-32

Plant: Nitric Acid

Acceptable Error: _____

Result Before Calibration:

Reference Data	Observed Data	Error (If any)
30 °C	111.67 Ω	/ Not /
40 °C	115.54 Ω	
60 °C	123.25 Ω	
80 °C	130.91 Ω	
100 °C	138.51 Ω	

Result After Calibration:

Reference Data	Observed Data	Error (If any)
/	/	/
/	/	/
/	/	/
/	/	/

Remarks (If Any): _____

14-09-2007 Date of Calibration	16-09-2008 Next Due Date	Saif + Munir Calibrated By
-----------------------------------	-----------------------------	-------------------------------