

## Calibration Performa

**Department:** Instrument

Instrument Tag: 07-TE-1-13

Instrument Name: RID

P&I No /Location: \_\_\_\_\_

Range: 30 ~ 100 °C

Calibration Frequency: One year

Instrument used for calibration: Temp Bath

Reference Document: OS-32

Plant: Nitric Acid (L-C)

Acceptable Error: \_\_\_\_\_

**Result Before Calibration:**

Reference Data	Observed Data	Error (If any)
30 °C	111.67 Ω	Nil
40 °C	115.54 Ω	
60 °C	123.24 Ω	
80 °C	130.90 Ω	
100 °C	138.51 Ω	

**Result After Calibration:**

Reference Data	Observed Data	Error (If any)
/	/	/
/	/	/
/	/	/
/	/	/
/	/	/

Remarks (If Any): \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

27-08-2007 Date of Calibration	27-08-2008 Next Due Date	Munir + Saif Calibrated By
-----------------------------------	-----------------------------	-------------------------------