

 <b>CDM project activity issuance review form</b> <i>(By submitting this form, a Party involved (through the designated national authority) or an Executive Board member may request that a review is undertaken)</i>	
<b>Designated national authority/Executive Board member submitting this form (Name in print)</b>	
<b>Title of the proposed CDM project activity for which issuance is requested</b>	0578 Deoband Bagasse based Co-generation Power Project
<b>DOE that requested for issuance and date of request</b>	13/08/07 SGS
<b>Please indicate, in accordance with paragraphs 65 of the CDM modalities and procedures, for which reason(s) you request review. (Place a cross (X) in front of the reason)</b>	
<input type="checkbox"/> <i>Fraud</i> <input type="checkbox"/> <i>Malfeasance</i> <input checked="" type="checkbox"/> <i>Incompetence</i>	
<b>Please indicate reasons for the request for review and attach any supporting documentation to this request form. (if space is not sufficient please attach further reasons)</b>	
<p>1. The monitoring report and the spreadsheet do not present the data on the temperature and pressure of steam, while the monitoring plan and the methodology requires that these parameters be monitored in a continuous basis.</p> <p>2. The electricity generation by the project in March 2006 and January 2007 exceeded the maximum theoretical generating capacity of the plant (22.0 MW). Likewise the steam generated in January 2007 was higher than the maximum capacity of 120 TPH. Clarification is required.</p>	
<b>Section below to be filled in by UNFCCC secretariat</b>	
Date received at UNFCCC secretariat	25/08/2007