



CETHAR VESSELS (P) LIMITED

4, DINDIGUL ROAD
THIRUCHIRAPALLI - 620 001
TAMILNADU, INDIA
TEL: 91-431-2484000
FAX: 91-431-2481079
E-mail:
externalservices@cethar.com
Website: www.cethar.com

TO

M/s SKS ISPAT LIMITED,
RAIPUR,
CHHATTISGARH STATE.

DATE: 22/06/07.

KIND ATTN: U.C. PRASAD,
PRESIDENT POWER PLANT.

DEAR SIR,

SUB: BOILER OPERATION HANDLED OVER - REQ.
(110TPH, 6TKG/CM², 495°C AFBC BOILER)

WE ARE VERY MUCH THANKFULL FOR YOUR KIND
CO-OPERATION DURING ERECTION & COMMISSIONING OF
110TPH AFBC BOILER.

(*) THE BOILER WAS COMMISSIONED SUCCESSFULLY AND
THE SAFETY VALVE SETTING HAD COMPLETED ON 18/05/07.
(*) THE BOILER HAVE BEEN STARTED ON 01st JUNE 2007.
AND IT HAS BEEN OPERATED UPTO 74TPH HENCE
WE GLAD TO INFORM YOU THAT THE BOILER OPERATION
HANDLED OVER TO M/s SKS ISPAT LIMITED.

(*) M/s CVPL REQUESTED TO M/s SKS ISPAT TO MAINTAIN
WATER QUALITY REQUIREMENT AS PER OUR CVPL
SPECIFICATION. THE WATER QUALITY REQUIREMENT
ARE ENCLOSED ALONG WITH THIS LETTER FOR YOUR
REFERENCE.

(*) M/s CVPL REQUESTED TO M/s SKS ISPAT TO MAINTAIN
THE BOILER OPERATING PARAMETER LOG SHEET
FOR FUTURE ANALYSIS AND TO MAINTAIN BED MATERIAL
SIZE & QUALITY AS PER OUR CVPL SPECIFICATION FOR
BETTER AND SMOOTH OPERATION OF BOILER.

THANKING YOU,

YOURS FAITHFULLY,
22/06/07
Jeeva.A