

**DAILY REPORT OF POWER GENERATION
EXCLUSIVE POWER REPORT**

DATE: 03/06/07

Serial No.	PARTICULARS	UNITS	TODAY	TO DATE
1	POWER GENERATION	KWH (A)	4,97,000	13,08,000
		Average MW	20.71	
2	Auxiliary Power Consumption(operation)	KWH	36,610	98,740
		Average MW	1.52	
	Project Power	KWH	10,000	
	Total	KWH	46,610	1,28,740
3	Import from CSEB	KWH (B)	26,500	1,91,500
		Average MW	1.10	
	Export to CSEB	KWH (C)	87,000	1,99,500
		Average MW	3.62	
4	Total Plant Power Consumption	KWH (A+B-C)	4,36,500	13,00,000
		Average MW	18.19	
5	Import Power Factor	At 6.00 Hrs.	0.736	

TURBINE GENERATOR	A SHIFT	1,79,000 KWH	*497MWH	231MW from Boiler# 1,2&3	*Excluding Additional Generation 266MW (Boiler#5). T.G desynchronized at 2.55 pm due to low steam temperature. T.G synchronized at 3.32 pm.
	B SHIFT	1,51,000 KWH			
	C SHIFT	1,67,000 KWH			

DY. General Manager (Power)