

**DAILY REPORT OF POWER GENERATION
EXCLUSIVE POWER REPORT**

DATE: 04/06/07

Serial No	PARTICULARS	UNITS	TODAY	TO DATE
1	POWER GENERATION	KWH (A)	4,02,000	17,10,000
		Average MW	16.75	
2	Auxiliary Power Consumption(operation)	KWH	37,310	1,36,050
		Average MW	1.55	
	Project Power	KWH	10,000	
	Total	KWH	47,310	1,76,050
3	Import from CSEB	KWH (B)	68,000	2,59,500
		Average MW	2.83	
	Export to CSEB	KWH (C)	55,000	2,54,500
		Average MW	2.29	
4	Total Plant Power Consumption	KWH (A+B-C)	4,15,000	17,15,000
		Average MW	17.29	
5	Import Power Factor	At 6.00 Hrs	0.826	

TURBINE GENERATOR	A SHIFT	1,78,000 KWH	*402MWH	245MW from Boiler#1,2,3&4	Excluding additional generation 157 MW (boiler-5) TG desynchronized at 2.55 pm due to low steam temperature. T.G synchronized at 3.32 pm.
	B SHIFT	1,26,000 KWH			
	C SHIFT	98,000 KWH			


DY. General Manager (Power)