



## REVIEW OF THE PROJECT ACTIVITY

### “Sichuan Tongjiang Gaokeng Hydropower Station Project” (2147)

At its forty-sixth meeting the Board could not register the project activity “Sichuan Tongjiang Gaokeng Hydropower Station Project” (2147), submitted for registration by the DOE (TÜV-SÜD), because the DOE and project participant failed to substantiate why the project developer chose to construct a plant of the scale considered for the project activity, rather than a scale which would be capable of evacuating a larger percentage of its output to the grid as it has been confirmed that the transmission constraints have been reported prior and in parallel to the implementation of the project activity and are unlikely to be resolved by 2020 for small scale hydropower stations in Eastern Sichuan.

-----